



PRITAM INDIA

Complete firefighting and safety solution



REF NO. PI/AGT/326/2026

DATE-28.07.2026

TO WHOM IT MAY CONCERN

This is to Certify That the Following Fire Extinguisher Were Checking/Testing/Refilling /Reconditioning/Service Done by Us at Your Site and Make+ Them Ready for Further Service

Party Name & Address : Golden valley H.S.(+2STAGE) SCHOOL
Dharmangar, Tripura
Vehicle No & Catagory :
Type Of Fire Extingulsher - : ABC S/P & co2 Type Fire Extingulsher
Quantity Of Fire Extinguisher : 04 (four) No's
Capacity Of Fire Extinguisher : ABC s/p 04 kg-02 no's, co2 02 kg-01 no, co2 4.5kg-01 no

Dry Chemical Powder Condition: ISI mark & good condition

Stored Pressure Condition :Dry n2 gas pressure "ok" condition

Co2 Weight :-

Date Of Checking : 29-07-2026

Date Of Refilling / Testing : 29-07-2026

Next Refilling Due On : 28-07-2027

FOR, PRITAM INDIA



AUTHORISED SIGNATORY